



# VAEWD-D001 Wireless Remote Controller INSTALLATION MANUAL

ENGLISH

- ✓ Read this Manual before the operation and keep it for reference.
- ✓ Read all safety precautions on the manual, improper use can cause serious injury.

Specification and performance data listed herein are subject to change without notice



Is a product of  Environmental Technologies LLC.

# Contents

---

Installation .....	1
1. Installation Precautions .....	1
2. Installation Accessories .....	3
3. Dimensions of Remote Controller and Bracket .....	3
4. Installation and Fixing .....	4
5. Replace the Batteries .....	5
Operating the Remote Controller .....	7
1. Using Precautions .....	7
2. Model and Key Parameters .....	8
3. Button Names and Functions .....	9
4. Name and Function on Display Screen .....	11
5. Operating Methods .....	12
5.1 On/Off Operations .....	12
5.2 Mode and Temperature Operations .....	12
5.3 Fan Speed Operations .....	13
5.4 Fan Direction Operations .....	14
5.5 Swing Operation .....	14
5.6 IDU Display Operations .....	15
5.7 Silent Mode Operation .....	16
5.8 ECO Operations .....	16
5.9 Follow Me Operations .....	17
5.10 Timer On/Off Operations .....	17
5.11 Button Lock Operations .....	19
5.12 Auxiliary Heater Operations (reserved) .....	19
Field Settings .....	20
1. Indoor Unit Address Query and Setting .....	20
2. Parameter Configuration for Remote Controller .....	22

# Installation

---

## 1. Installation Precautions

### Safety Considerations

Please read this "Safety Considerations" carefully before installing Controller and be sure to install it correctly. After completing the installation, make sure the controller operates properly.

Please instruct the customer how to operate the controller and how to perform maintenance.

### Meaning of Caution Symbols



Failure to observe these instructions properly may result in property damage or personal injury.

---

Information classified as **NOTE** contains instructions to ensure proper use of the controller.

---



- Ensure that nothing interrupts operation of the wireless remote controller.
- Ensure that the signal from the remote controller can easily be transmitted.
- Ensure that the operation display lamp and other indicator lamps can easily be seen.
- Ensure that there is neither a source of light nor a fluorescent lamp near the receiver.
- Ensure that the receiver is not exposed to direct sunlight.

# Installation

---



## WARNING

### Precautions in handling remote controller

- Direct the transmitting part of the remote controller to the receiving part of the air conditioner.
- If something blocks the transmitting and receiving path of the indoor unit and the remote controller as curtains, it will not operate.



- Transmitting distance is approximately 7 m.
- 1 short beeps from the receiver indicates that the transmission is properly done.
- Do not drop or get it wet.  
It may get damaged.
- Never press the button of the remote controller with a hard, pointed object.  
The remote controller may get damaged.






### Installation site

- It is possible that signals will not be received in rooms that have electronic fluorescent lighting. Please consult with the salesman before buying new fluorescent lights.
- If the remote controller operated some other electrical apparatus, move that machine away or consult your dealer.

# Installation

## 2. Installation Accessories

- Please check that you have all the following parts.

No.	Name	Schematic	Qty
①	Remote controller bracket		1
②	Screw lid		1
③	Philips head screw (M2.0*4.5)		2
④	AAA battery		2
⑤	Remote controller manual		1

## 3. Dimensions of Remote Controller and Bracket




Figure 2.1 Dimensions of remote controller

# Installation

---




Figure 2.2 Dimensions of remote controller bracket

## 4. Installation and Fixing

1) Use the screws (accessories) to fix and secure the remote controller bracket in a stable position (see Figure 2.3);

Make sure you refer to "1. Installation Precautions" to determine the location.




Figure 2.3

2) Slot the screw lid into the bracket cover on top of the screws (see Figure 2.4);

# Installation

---




Figure 2.4

3) Slide the remote controller vertically down into the remote controller bracket (see Figure 2.5).




Figure 2.5

## 5. Replace the Batteries

1) Slide to move the battery cover at the back of the remote controller in the direction indicated by the arrow (Figure 2.6);

# Installation

---




Figure 2.6

2) Lift up from the lower left end of the battery cover to open it (see Figure 2.7);




Figure 2.7

3) Take out the old batteries. Install two new AAA batteries according to the positive and negative polarities indicated (see Figure 2.8). Close the battery cover.




Figure 2.8



# Operating the Remote Controller

---

## 1. Using Precautions

To gain full advantage of the controller's functions and to avoid malfunction due to mishandling, we recommend that you read this instruction manual carefully before use.

The precautions described herein are classified as **WARNING** and **CAUTION**. They both contain important information regarding safety. Be sure to observe all precautions without fail.

---



### **WARNING**

Failure to follow these instructions properly may result in personal injury or loss of life.



### **CAUTION**

Failure to observe these instructions properly may result in property damage or personal injury, which may be serious depending on the circumstances.

---

Information classified as **NOTE** contains instructions to ensure proper use of the controller.

After reading, keep this manual in a convenient place so that you can refer to it whenever necessary. If the controller is transferred to a new user, be sure also to hand over the manual.

---



### **WARNING**

Note that prolonged, direct exposure to cool or warm air from the air conditioner or to air that is too cold or warm can be harmful to your physical body and health.

- Do not use pesticides, disinfectants and flammable sprays to spray directly on the remote controller as these may cause the device to become deformed.
  - If there is a fault with the remote controller, turn off the remote controller and contact your local agent.
  - Remove the dry batteries before cleaning or maintenance of the remote controller. Do not wash the controller with water.
-

# Operating the Remote Controller

---



## CAUTION

- Do not operate the device with wet hands to prevent water from entering the remote controller and damage the circuit board.
  - Do not use the air conditioner for purposes other than those for which it is intended. Do not use the air conditioner to cool precision instruments, food, plants, animals or works of art as this may adversely affect the performance, quality, and/or lifespan of the object concerned.
  - Ventilate the area from time to time. Be careful when you use the air conditioner with other heating equipment. Insufficient ventilation may result in oxygen deficiency.
- 

## 2. Model and Key Parameters

<b>Product Model</b>	RM12D
<b>Rated Voltage</b>	3.0 V (AAA battery x 2)
<b>Ambient Temperature</b>	-5 to 43°C
<b>Ambient Humidity</b>	RH ≤ 90%

# Operating the Remote Controller

## 3. Button Names and Functions





















Figure 3.1 External view of remote controller

# Operating the Remote Controller

No.	Button	Function
①	 ECO	Turn on/off the economic operation function
②	 Mode	Set operating mode: Auto → Cool → Heat → Dry → Fan
③	 Adjust downwards	Adjust the temperature setting or timer (programmed time) downwards
④	 Display	Turn on or off the display of the indoor unit
⑤	 Timer on	Set the time to turn on the unit
⑥	 Silent	Turn on/off the silent function
⑦	 Follow me	Turn on/off the follow me function
⑧	 Auxiliary heater	Turn on/off the auxiliary heater function
⑨	 Adjust upwards	Adjust the temperature setting or timer (programmed time) upwards
⑩	 On/off switch	Switch on/off the unit
⑪	 Fan speed	Fan speed setting
⑫	 Timer off	Set the time to turn off the unit
⑬	 Fan direction	Adjust the direction of the horizontal louver
⑭	 Vertical swing	Turn on/off the vertical swing function
⑮	 Horizontal swing	Turn on/off the horizontal swing function

# Operating the Remote Controller

## Note:

- The buttons  and  are not available for first generation indoor units.

## 4. Name and Function on Display Screen




Figure 3.2 Display screen of remote controller



No.	Name	Display Function
①	Temperature	Displays current temperature setting
②	Vertical swing	Shows that Vertical Swing is on
③	Horizontal swing	Shows that Horizontal Swing is on
④	Silent mode	Shows that Silent is on
⑤	Follow me	Shows that Follow Me is on
⑥	Operating mode	Displays the current operating mode
⑦	Signal transmission	Displays signal sent to the indoor unit from the remote controller

# Operating the Remote Controller

⑧	Power-on display	Indicates a unit is turned on
⑨	Fan speed	Displays the current fan speed
⑩	Timer On/Off	Displays times to turn on/off the unit
⑪	Lock	Shows that the remote controller button is locked
⑫	ECO	Shows that ECO function is on
⑬	Auxiliary heater	Shows that auxiliary heater is on

## 5. Operating Methods

### 5.1 On/Off Operations

1) Press  (see Figure 3.3), and the remote controller displays the  icon on its screen. Indoor unit starts to run;






Figure 3.3

2) Press  again. The  icon disappears from the display screen of the remote controller, and the indoor unit stops running.

### 5.2 Mode and Temperature Operations

1) Press  (see Figure 3.4). Display screen shows the operating mode;





Figure 3.4

# Operating the Remote Controller

2) Press  each time to change the operating mode according to the order shown in Figure 3.5;








Figure 3.5

3) In Auto, Cool, Dry or Heat mode, press  and  to adjust the temperature setting. Press  and  to adjust the temperature by 1°C (default). Long press to change the temperature continuously.

Note:

- Fan speed cannot be adjusted in the Auto and Dry modes.
- Temperature setting cannot be adjusted in the Fan mode.

## 5.3 Fan Speed Operations

In Cool, Heat or Fan mode, press  to set the operating fan speed (see Figure 3.6).




Figure 3.6

1) 7 fan speeds: The default in the remote controller is the mode with 7 fan speeds, where the Fan Speed will be adjusted in turn as shown in Figure 3.7;




Figure 3.7

2) 3 fan speeds: Fan Speed will be adjusted in turn as shown in Figure 3.8.




Figure 3.8

Note: the default fan speed is 7 fan speeds, please refer to Field Setting to adjust the default fan speed.

# Operating the Remote Controller

## 5.4 Fan Direction Operations

Press  to adjust the direction of the vertical louver (see Figure 3.9).




Figure 3.9


1) For second generation indoor units, there are 5 swing angles, and the vertical louver swings by a particular angle each time the button is pressed (see Figure 3.10);



Figure 3.10



2) For first generation of indoor units, the vertical louver will swing by about 6 degrees each time the button is pressed.

Note:

- Only valid for indoor units with vertical louvers.
- When the unit is off, the  button is invalid. When the unit is turned off, the remote controller automatically turns off the vertical louver direction function.

## 5.5 Swing Operation

1) Vertical Swing

① When the unit is on. Press  (see Figure 3.11). Start the vertical swing function, and the  icon will light up, and signal is sent to the indoor unit;






Figure 3.11




# Operating the Remote Controller

② When the vertical swing is on, press  to turn off this function.

Note:

- When the unit is turned off, the  button is invalid.
- Each time the vertical swing signal is sent, the icon keeps lighting up for 15s and then disappears. The indoor unit remains vertical swing operation.

## 2) Horizontal Swing

① When the unit is on. Press  (see Figure 3.12). Start the horizontal swing function, and  will light up, and signal is sent to the indoor unit;






Figure 3.12


② When the horizontal swing is on, press  to turn off the horizontal swing function.

Note:

- When the unit is turned off, the  button is invalid.
- Each time the horizontal swing signal is sent, the icon keeps lighting up for 15s and then disappears. The indoor unit remains horizontal swing operation.

## 5.6 IDU Display Operations

The Display function is used to control the on/off state of the display in the indoor unit.

1) When the remote controller is in on or off state, press  (see Figure 3.13), and the display of the indoor unit lights up;







Figure 3.13

# Operating the Remote Controller

2) When the display of the indoor unit lights up, press  to turn off the light.

## 5.7 Silent Mode Operation

The Silent function is used by the remote controller to send the "Silent" signal to the indoor unit. The indoor unit automatically optimizes the noise it generates when it is in the "Silent" mode.

1) When the unit is in the Cool or Heat mode, press  (see Figure 3.14) to start the Silent function. Screen displays the  icon;







Figure 3.14



2) In Silent mode, press  to turn off the Silent function, and the  icon will disappear.

Note:

- Once it has been running for 8 hours,  will no longer light up, and the unit will exit the Silent mode.
- The Silent and ECO functions cannot be implemented at the same time.

## 5.8 ECO Operations

The remote controller can send the ECO signal to the indoor unit when the unit is operating in Cool or Heat mode.

1) Press  (see Figure 3.15) to send the ECO signal to the indoor unit. The  icon is displayed;

2) Then press ,  or  to exit the ECO function. The  icon disappears.







Figure 3.15

# Operating the Remote Controller

Note:

- In cooling mode, when ECO is set up, the Fan Speed is forced to Auto and the temperature is 26°C; in heating mode, when ECO is set up, the Fan Speed is forced to Auto and the temperature does not change.
- Once it has been running for 8 hours,  will no longer light up, and the unit will exit the ECO mode.
- The Silent and ECO functions cannot be implemented at the same time.

## 5.9 Follow Me Operations

1) When the unit is in the Cool, Heat or Auto mode, press  to start the Follow Me function. The screen will display the  icon (see Figure 3.16);







Figure 3.16

- 2) The remote controller will send the ambient temperature of the remote controller surroundings to the indoor unit every 3 minutes;
- 3) When the Follow Me function is on, press  to turn off this function, and the  icon will disappear from the display.

## 5.10 Timer On/Off Operations

"Timer" is used to set the timed on/off state of indoor unit.

1) Timer On Operation:

- ① Press  (see Figure 3.17), and the remote controller will display "Timer On", and "0.0h Later On" will appear in the timer area. Adjust the Timer On settings now;

# Operating the Remote Controller





Figure 3.17

- ② Press  or ▲, ▼ to adjust the timer settings;
- ③ Once the adjustment is done, the timer information is sent to the indoor unit.

## 2) Timer Off Operation:



- ① Press  (see Figure 3.18), and the remote controller will display "Timer Off", and "0.0h Later Off" will appear in timer area. Adjust the Timer Off settings now;



Figure 3.18

- ② Press  or ▲, ▼ to adjust the timer settings;
- ③ Once the adjustment is done, the timer information is sent to the indoor unit.

## Note:




- Long press the timer adjustment buttons to adjust the time in units of 0.5 hours. If the adjustment exceeds 10 hours, the changes will be in units of 1 hour, and the maximum time setting is 24 hours.
- Adjust the Timer On or Timer Off to 0.0h to cancel the Timer On or Timer Off settings.

# Operating the Remote Controller

- When the Timer settings have been completed, there may be a  $\pm 15$  minutes time difference when the buttons for adjustment, mode, fan speed and ECO are pressed again.
- The Timer On and Timer Off settings can be set at the same time.

## 5.11 Button Lock Operations

Once the buttons on the remote controllers are locked, all the other button operations except for Unlock and IDU Address Setting are invalid.

- 1) Press  and  at the same time to lock the button (see Figure 3.19), and the screen will display the lock icon ;







Figure 3.19

- 2) Press  and  at the same time, and the lock icon  will disappear. Button is unlocked.

## 5.12 Auxiliary Heater Operations (reserved)

# Field Settings

## 1. Indoor Unit Address Query and Setting

Long press the buttons for + + at the same time for 8 seconds (see Figure 4.1) to go to the page to set the address of the indoor unit. Long press the same buttons again for 8 seconds or press to exit.




Figure 4.1

### 1) Indoor Unit Address Query:

Once in the address setting page, press the button to enter the Send page. In Send page, press the mode button to send the query command (see Figure 4.2), and the indoor unit display will show the IDU's current address.








Figure 4.2

## Field Settings

---

### 2) Indoor Unit Address Setting:

Once in the address setting page, press the  button to enter the Send page. In Send page, press  and  to adjust the address up and down respectively. Press  to send the address to the indoor unit. (See Figure 4.3)






Figure 4.3

# Field Settings

## 2. Parameter Configuration for Remote Controller

1) Configuration Method:

① Long press  and  on the remote controller at the same time for 5 seconds to go to the parameter settings status (see Figure 4.4);








Figure 4.4

② Press  and  to adjust the parameter value;

③ Once the adjustment is done, press  or wait for 5 seconds to save the parameter settings. The operation sequence for the button is as shown in Figure 4.5.





## Field Settings




Figure 4.5

2) See Table 4.1 for details.

Table 4.1 Parameters of remote controller

Parameter	Parameter Definition
00	7 fan speeds, temperature adjustment step of 0.5°C
01	3 fan speeds, temperature adjustment step of 1°C
02	7 fan speeds, temperature adjustment step of 1°C (default parameter)
03	3 fan speeds, temperature adjustment step of 0.5°C

Note:

- For the first generation indoor units, please set the parameter to 01.



**OMEGA**  
ENVIRONMENTAL  
TECHNOLOGIES LLC.

17702 Mitchell North, #101  
Irvine, CA. 92614 .USA  
Tel: 714 795 2830  
Fax: 714 966 1646  
info@omegavrf.com  
www.omegavrf.com

**OTEC**<sup>TM</sup>  
AIR CONDITIONING

**Showroom & Technology Center**  
11380 Interchange Circle North  
Miramar, FL 33025 .USA  
Tel: 305 901 1270  
Fax: 954 212 8280  
info@otecvrf.com  
wwwotecvrf.com

VAEWDCM-IM1D0620